

PARAMETERS	DG MODELS
EGenset Prime Rating (kVA) *	320
Genset Prime Rating (KW)	256
Phase / Voltage (V)	3 / 415
No of Phases	1/3
Power Factor	0.8 (lagging)
Current (A) (3Phase)	445
Frequency (Hz)& RPM	50/1500
Governing class	G2
Starting system	24 V DC Elec
Fuel tank capacity	570
Genset Dimension (LxWxH) (mm) Approx.	4550 X 1600 X 1780
Genset Weight (kg) approx.	3550
Engine Specification	
Make / Series	Mahindra mPower
Engine Model	mPower63905G
Rated Power at 100% Load @ 1500 RPM (HP)	390
Aspiration	Turbocharged Aftercooled
No. of cylinders	6
Bore x Stroke (mm)	116.6 x 146.1
Displacement (Lit)	9.3
Fuel consumption @ 75% load (lit/hr) ^	51.5
Fuel consumption @ 100% load (lit/hr) ^	67.4
Lube oil specification	15W40 CI4+
Lube Oil Refil Quantity (Lit)	30
Lube oil consumption @ 100% load (\$)	0.1% of Fuel Consumption
Lube oil change period (hrs.)	500
Radiator coolant capacity (liter)	45
Alternator	
Make	CG/Stamford
Enclosure Type	IP23
Voltage regulation	±1%
Class of insulation	Class H
Maximum Unbalanced Load across Phases	25%

**Alternator Configuration available

Above specifications are subject to change without prior notice due to continuous product improvements.

All engines & alternators confirm to respective IS standards

All the genset specifications are as per ISO 8528 standard

* For Standby duty, contact Powerol authorized representative

All specifications are at standard NTP operating conditions

All specifications are at standard NTP operating conditions

All the above gensets conform to the latest CPCB norms of <75 dbA